

Certificate

Applicant: KOSTAL Solar Electric GmbH
Hanferstraße 6
79108 Freiburg i. Br.
Germany

Product: Photovoltaic Inverter with integrated automatic disconnection device between a generator and the public low-voltage grid

Model:	PIKO 20	PIKO 17	PIKO 15
Rating:	20,0kW	17,0kW	15,0kW

Intended use:

An automatic disconnection device with three-phase mains surveillance in accordance with Engineering Recommendation G59/3 for photovoltaic systems with a three-phase parallel coupling via an inverter to the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

**Engineering Recommendation G59/3
Issue 3 – September 2013**

Recommendations for the connection of generating plant to the distribution systems of licensed distribution network operators

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 13KFS114-15

Certificate No: 14-087-00

Date of issue: 2014-07-16

Valid until: 2017-04-09




Andreas Aufmuth
Certification Department

